

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Annual Periodical Renewal Fire Certificate**

From:
District Fire Officer
Andhra Pradesh, Nellore

To:
{1} The Concerned Authority, Central Board
of Secondary Education {2} The Regional Joint
Director, School Education, Govt of AP,
{3} The District Educational Officer, SPSR
Nellore District

File No: 15643/NLR/DFO/2020, Date: 23/12/2020

Occupancy NoC RC Number: 1962/NLR/DFO/2018, Dt: 01-03-2018 of the DFO, NLR

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Amberwood International School, represented by Sri. Abburu Venkatesh, located at Sy.No: 216/1A, 217/1A, 221/A, 222/A & 226, Kondayapalem(V), Nellore Municipal Corporation, SPSR Nellore District Belongs to Sri. Abburu Venkatesh & S/O Late Abburu Sundararamaiah & Smt. Abburu Jayalakshmi W/o Abburu Venkatesh - Regarding.**

- Ref:**
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 1962/NLR/DFO/2018, Dt:01-03-2018 of the DFO, NLR, Dt.01/03/2018
 4. Renewal NOC For Occupancy 1962/NLR/DFO/2018, Dt:01-03-2018 of the DFO, NLR, Dt.01/03/2019
 5. Online Application for Renewal NOC of Sri. Abburu Venkatesh, located at Sy.No:216/1A, 217/1A, 221/A, 222/A & 226, Kondayapalem(V), Nellore Municipal Corporation, SPSR Nellore District Belongs to Sri. Abburu Venkatesh & S/O Late Abburu Sundararamaiah & Smt. Abburu Jayalakshmi W/o Abburu Venkatesh - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 23-12-2020.

<< 0 >>

The Management of Amberwood International School, represented by Sri. Abburu Venkatesh, located at Sy.No:216/1A, 217/1A, 221/A, 222/A & 226, Kondayapalem(V), Nellore Municipal Corporation, SPSR Nellore District Belongs to Sri. Abburu Venkatesh & S/O Late Abburu Sundararamaiah & Smt. Abburu Jayalakshmi W/o Abburu Venkatesh has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.151823/- vide challan No. 41248993972020, Dated 03/12/2020 at SBI, Through CFMS Challana.

Amberwood International School located at Sy.No:216/1A, 217/1A, 221/A, 222/A & 226, Kondayapalem(V), Nellore Municipal Corporation, SPSR Nellore District

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate Sri. **Abburu Venkatesh located at Sy.No:216/1A, 217/1A, 221/A, 222/A & 226, Kondayapalem(V), Nellore Municipal Corporation, SPSR Nellore District Belongs to Sri. Abburu Venkatesh & S/O Late Abburu Sundararamaiah & Smt. Abburu Jayalakshmi W/o Abburu Venkatesh, subject to the following conditions.**

SI	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 01/03/2020 to 28/02/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.


The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

☐ This Renewal NOC is issued form Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.

☐ The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the Responsibility of Fire Fighting equipment maintenance lies with the management as seen & tested by the committee at the time of inspection

☐ It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per Clause (2) of GO.Ms.No:169, HOME(Fire & Prisons) Dept, Dt:19-12-2019. two months before expire of this Renewal No Objection Certificate.

☐ The Management shall submit the Declaration to this office as per Clause 4.II(b) of GO.Ms.No:169, HOME(Fire & Prisons) Dept ,Dt:19-12-2019 for every year during the renewal period or otherwise this No objection certificate deemed to be cancelled.



15643/NLR/DF0/2020

Your Sincerely,

[Signature]
District Fire Officer
Andhra Pradesh, Nellore

Copy to Management Sri. Abburu Venkatesh, Amberwood International School located at Sy.No:216/1A, 217/1A, 221/A, 222/A & 226, Kondayapalem(V), Nellore Municipal Corporation, SPSR Nellore District Belongs to Sri. Abburu Venkatesh & S/O Late Abburu Sundararamaiah & Smt. Abburu Jayalakshmi W/o Abburu Venkatesh.
Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned